

Declaration Of Conformity

Brand : Senses Akustik
Product : Sora (Curtain Divider)
Product No. : DOC-SORA-R0-0925

Fire Rating on component level

Fabrics

- BS 5867-2:2008** : Flammability Test
Test Standard: BS 5867-2:2008
 Tested according to EN-ISO 15025:2002 Face Ignition
 Results: Satisfactory Pass to BS 5867: Part 2: Type B 2008
- BS 5852: 2006** : Flammability Test
Test Standard: BS 5852: 2006
 Ignition Source 5
 Results: Pass to BS 5852: 2006
- BS 5867-2:2008** : Fire Test according to BS 5867-2: 2008
 Fabrics for curtain, drapes and window blinds-Part 2: Flammability Req.
Test Standard: BS 5867-2:2008
 Test method to EN-ISO 15025:2002 procedure "A"
 The sample submitted complies with flammability requirements of BS 5867-2: 2008 for Type C performance.

Note: Individual fabric reports available on request

Acoustic Performance

- ASTM C423** : NRC: 0.3-0.9
ISO 11654 : Sound Absorption coefficient: 0.35-0.95

Note: Individual fabric reports available on request.

Date: September 2025